

XX006947 HOT-MIX ASPHALT DRIVEWAY REMOVAL AND REPLACEMENT

(LCDOT) For use on projects with the reconstruction of driveways. Generally, construction prefers to use N50 for driveway replacement due to the handwork required. If the project only has a handful of driveways then the HMA used should be the same as used on the road i.e. N70 (if that is what is on the roadway) in order to avoid multiple mix requirements. If there are many driveways then use the N50. What constitutes a handful vs many will be on a project by project basis in consultation with Construction. Revise the spec as required. Delete this note from the Contract Specifications.

Effective: June 6, 2011

Revised: October 10, 2022

Description: This work shall consist of completely removing and replacing existing private and commercial hot-mix asphalt (HMA) driveway pavement. The existing pavement may include HMA bases, overlays, and stabilized subbase.

General: The work shall be performed according to Section 440 of the "Standard Specifications" and the following:

The existing pavement shall be sawcut at the paving limit, one foot inside the right-of-way, or as designated by the Engineer. The removal shall include the existing pavement and aggregate base to a depth of 8½" for private entrances and 10½" for commercial entrances.

All removed materials shall be disposed of outside the limits of the right-of-way according to Article 202.03 of the "Standard Specifications" and/or as directed by the Engineer.

The driveway shall be replaced with a 6" lift of Aggregate Base Course, Type B for private entrances or an 8" lift of Aggregate Base Course, Type B for commercial entrances. The aggregate shall meet the requirements of AGGREGATE BASE COURSE as specified herein. The aggregate base shall be surfaced with a 2½" lift of Hot-Mix Asphalt Surface Course, Mix "D", N50. N50 preferred - N70 (see notes above) Revise as required. Delete this note from the Contract Specifications.

Method of Measurement: Hot-Mix Asphalt Driveway Removal and Replacement will be measured for payment in place and the area computed in square yards.

Basis of Payment: This work will be paid for at the contract unit price per square yard for HOT-MIX ASPHALT DRIVEWAY REMOVAL AND REPLACEMENT. *The unit price shall include all equipment, labor and materials required to remove the driveway to the specified depth; transport and dispose of the removed material; furnish and place the aggregate base to the depth specified; and place the HMA surface course. The cost of saw cutting the driveway shall also be included in the unit price.*