



Department of Public Works

**Lake County Public Works Department  
Service Pipe Disconnection Requirements  
May 22, 2019**

1. All water and sewer services shall be disconnected at the main, unless otherwise approved by the Engineering Supervisor. Additional permit may be required from the ROW authority.
2. Disconnected service pipes may be reused if a connection permit has been issued and if the pipe is in suitable condition for reuse. Sewer service pipes must be televised in the presence of a LCPW inspector.
3. Inspections must occur prior to backfill of the disconnection point. Contact LCPW at 847-377-7500 to schedule inspections 48 hours in advance.
4. Only LCPW personnel are authorized to operate mainline valves.
5. Water services shall be capped by installation of a copper blank at the corp with proper bedding.
6. The applicant is responsible for all approvals from the applicable roadway authority, including provisions for emergency vehicle access and neighbor notification.