



NOTES:

- ① UTILIZE FULL BODY SERVICE SLEEVE FOR PVC AND DUCTILE IRON WATERMAIN (SMITH BLAIR #372)
- ② UTILIZE ELECTROFUSION SERVICE SLEEVE FOR HDPE WATER MAIN (FRIATEC 'VA')
- ③ TRACER BOX AND TRACER WIRE REQUIRED ONLY IF SERVICE PIPE IS NOT COPPER
- ④ TRACER WIRE ACCESS BOX COPPERHEAD INDUSTRIES OR EQUAL. LAWN AREAS LD14. PAVED AREAS RB14.
- ⑤ SERVICE MATERIAL FROM MAIN TO B-BOX CAN ONLY BE TYPE K COPPER
- ⑥ FULL PAD REPAIR SLEEVE REQUIRED FOR EXISTING TRANSITE/ACP PIPE

HDPE PIPE SHALL BE PE 4710 DR9 RATED FOR A MINIMUM OF 160 PSI AND IN ACCORDANCE WITH AWWA C901. HDPE PIPE MAYBE PERMITTED IN LIEU OF COPPER FROM CURB BOX TO HOUSE. ANY OTHER MATERIAL FROM CURB BOX TO HOUSE TO BE APPROVED BY LCPW PRIOR TO INSTALLATION.