



NOTES:

1. GATE VALVE SHALL HAVE STAINLESS STEEL HARDWARE
2. STAINLESS STEEL VALVE STEM EXTENSION MAY BE REQUIRED IF STANDARD 8 FT VALVE KEY WILL NOT EXTEND 3 FT ABOVE FINISHED GROUND DURING OPERATION. USE OF VALVE STEM EXTENSION SHALL BE AT THE DISCRETION OF LCPW.

DATE: 6/26/15	ID: 5
REVISIONS DATE	
ENG-MAIN, UPDATE 9/20/18 ENG-MAIN, UPDATE 12/14/20	