



**NOTE:**

1. CONTRACTORS WILL SUPPLY HYDRANTS WITH ATTACHED AUXILIARY VALVES.
2. COLOR OF HYDRANT TO BE PITTSBURG 90-330 YELLOW.
3. IF DITCH ELEVATION PREVENTS 5'-6" MINIMUM COVER OVER HYDRANT LEAD, CONTRACTOR SHALL ROLL HYDRANT TEE DOWN AND PROVIDE VERTICAL BENDS BETWEEN TEE AND AUXILIARY VALVE.
4. HYDRANT AND VALVE AND ALL FITTINGS SHALL HAVE STAINLESS STEEL HARDWARE

DATE: 6/26/15	ID: 9
REVISIONS	DATE
ENG-MAIN. UPDATE	8/21/18
ENG-MAIN. UPDATE	9/20/18