



NOTE:

1. SANITARY SEWER SERVICE RISERS TO BE CONSTRUCTED WHERE MAIN LINE SEWER DEPTH EXCEEDS 12'-0".
2. USE NON SHEAR MISSION COUPLING TO CONNECT DISSIMILAR MATERIALS
3. THERE SHALL BE AT LEAST ONE CLEANOUT ON EACH SANITARY SERVICE LINE LOCATED AT LEAST 5 FEET OUTSIDE THE BUILDING. CLEANOUTS SHALL BE INSTALLED NO MORE THAN 100 FEET APART AND AT EACH CHANGE OF HORIZONTAL DIRECTION OF 60° OR GREATER.
4. CLEANOUTS SHALL BE UNOBSTRUCTED WITH A MINIMUM 18 INCHES OF CLEARANCE.