



NOTE:

1. SANITARY SEWER RISERS TO BE CONSTRUCTED IN LIEU OF T-WYES WHERE SEWER DEPTH EXCEEDS 8'-0".
2. USE NON SHEAR MISSION COUPLING TO CONNECT DISSIMILAR MATERIALS
3. THERE SHALL BE AT LEAST ONE CLEANOUT ON EACH SANITARY SERVICE LINE LOCATED AT LEAST 5 FEET OUTSIDE THE BUILDING. CLEANOUTS SHALL BE INSTALLED NO MORE THAN 100 FEET APART AND AT EACH CHANGE OF DIRECTION (HORIZONTAL) GREATER THAN 60 DEGREES.
4. CLEANOUTS SHALL BE UNOBSTRUCTED WITH A MINIMUM 18 INCHES OF CLEARANCE.