



- ① A. UTILIZE FULL BODY SERVICE SLEEVE FOR PVC PIPE (SMITH BLAIR #372)
- B. UTILIZE ELECTROFUSION SERVICE SADDLE FOR HDPE PIPE (FRIATEC 'VA')

- 1. EXTERNAL VENTING MAYBE REQUIRED BASED ON SYSTEM AND DISCRETION OF LCPW ENGINEERING SUPERVISOR.
- 2. IF INTERNAL VENTED THE CONCRETE SHALL HAVE CONSHIELD OR HAVE AN APPROVED BIOGENIC CORROSSION RESISTANT LINER.

DATE: 6/26/15	ID: 12
REVISIONS      DATE	
ENG-MAIN. UPDATE 8/21/18 ENG-MAIN. UPDATE 12/14/20	